


South Mechanical Room

North Mechanical Room



Fresh Air Intake

Exhaust Vent

Fresh Air Intake

Exhaust Vent

## Appendix B

**Blueprint Reference List for Exhaust Fans (EF) Note that Most Service Restrooms or Mechanical Systems**

FAN SCHEDULE											
ITEM NO.	MODEL	TYPE	SERVICE	CFM	SP IN	RPM	HP	V	PH	HZ	
DEF-1	21	N-LINE	AC-1	2630	A	1197	3/4	208	3	60	
DEF-2	15		AC-2	1720		1564	1/2	208	3		
DEF-3	12		AC-3	1750		1576	1/2	208	3		
DEF-4	38		AC-4	3,950		789	3	208	3		A
DEF-5	18		AC-5	1920		1703	1/2	208	3		A
DEF-6	10		AC-6	910		1092	1/4	120	1		
DEF-7	21		AC-7	6120		1212	1 1/2	208	3		
DEF-8	10	✓	AC-8	1000	✓	1092	1/4	120	1	✓	
EF-1	20 DRE BX	DOOR	TOILETS	60	1/8"	1135	58	120	1	60	W
EF-2				60	1/8"	1135	125				
EF-3				180	3/8"	1135	1/2				
EF-4	10 DRE BX			135	3/8"	1200	1/4				
EF-5	22 DRE BX			975	1/2"	1270	1/2				
EF-6	10 DRE BX			240	3/4"	1280	1/4				
EF-7	30 DRE BX			120	1/4"	1134	3/4				
EF-8	22 DRE BX		✓	900	1/2"	1223	1/2				
EF-9	40 DRE BX		ELEC. RM	200	3/8"	1250	1/4				
EF-10	20 DRE BX		ELEC. RM	375	3/8"	1150	1/2				
EF-11	10 DRE BX		TOILETS	255	3/8"	1290	1/2				
EF-12	10 DRE BX	✓	KITCHEN	105	1/8"	1025	1/4	✓	✓	✓	
EF-13	185 B128F	IN-WALL	MECH. RM.	2329	1/4"	1072	1/2	208	3	60	
EF-14	2-8	CEILING	LOUNGE-CONF. RM.	200	1/8"	1050	1/4	120	1	60	
EF-15	2-10	CEILING	LOUNGE	375	1/8"	1050	1/4	120	1	60	

